

At least two pumpers and one ladder truck respond to all alarms of fire in the mercantile, manufacturing, school, and hospital districts, and two pumpers in the residential district, except where the telephone indicates an automobile fire, or fire other than in a building, the response may be only one pumper.

The present training program be expanded to include: instruction in fire department discipline, in the use and care of equipment, location of fire hydrants, fire methods, ladder practices, salvage and clean-up work, ventilation, rescue and first aid practices, inspections, fire hazards, municipal building and fire prevention ordinances, the use and effectiveness of various fire streams and portable extinguishers, the use of fire department connections to sprinkler systems, elementary fire department hydraulics, especially as applied to the Thomasville waterworks system, night evolutions, an analysis by field inspection of local building and hazard conditions from a fire fighting standpoint, and the making of sketches and filing of complete records of each inspection. A complete set of records of all training activities of the department be maintained in orderly and legible form.

All pumpers and hoses be tested at least once annually in accordance with standards established by the National Board of Fire Underwriters, with complete records to be kept on such tests.